

DEPARTMENT OF FIRE AND RESCUE SERVICES

GOVERNMENT OF KERALA

KONNI STATION

Book No: C/97

Date:-13.01.2025

CERTIFICATE OF APPROVAL

1. Name and address of the Applicant : Fr. Prince Koickal
Manager,
Carmal Central School
Payyanamon, P. O., Konni
2. Name of the Company : Carmal Central School
3. Occupancy Tyre of Building : Educational Building
4. Height of the Building : 12.2 Meters
5. No. of Floors of the Building : G+2(3Floor)
6. Total Plinth area (in sqm) : 304.22 M²
7. Survey No. : 247/2A6
8. Village : Ayravon
9. Grama Panchayath/
Municipality/Corporation : Konni Grama Panjayath
10. District : Pathanamthitta


GEORGE VARUGHESE, MA, MA, B.Ed.
PRINCIPAL
CARMAL CENTRAL SCHOOL
PAYYANAMON P.O., KONNI - 689 692




MANAGER BURSAR
CARMAL CENTRAL SCHOOL
PAYYANAMON P.O., KONNI,
PATHANAMTHITTA, KERALA - 689692

The above site and building were inspected by the authorized and competent officials of this department. The building has been constructed as per the Rules and Norms pertaining the Fire Safety arrangements. The existing and functioning of Carmal Central School, Payyanamon, Konni, Pathanamthitta, Building and Ward No. KP VII - 468, 468 A (276 A), at Konni Taluk, managed by Malankara Catholic Educational Society, Pathanamthitta, is suitable and safe to continue the function of the CBSE School on the fire and safety point of view. The surrounding buildings have no fire risk. There are suitable ways for the fire service vehicle to reach the school at the time of emergency. Necessary first aid fire fighting precautionary measures have been provided at the building as shown below. So there is no fire safety risk for the building on the fire point of view.

- | | | |
|--|---|--------|
| 1. ABC stored pressure type 5Kg Capacity ISI | - | 12 set |
| 2. Fire bucket with stand | - | 5 set |
| 3. 2000 litter capacity water tank on the building | - | 8 nos. |



(Handwritten Signature)
 സ്റ്റേഷൻ ഓഫീസർ
 അഗ്നിശമന രക്ഷാനിലയം
 കോന്നി - 689 691

(Handwritten Signature)
 GEORGE VARUGHESE, MA, MA, B.Ed.
 PRINCIPAL
 CARMAL CENTRAL SCHOOL
 PAYYANAMON P.O. KONNI - 689 692



(Handwritten Signature)
 MANAGER BURSAR
 CARMAL CENTRAL SCHOOL
 PAYYANAMON P.O., KONNI.
 PATHANAMTHITTA, KERALA - 689692